



- Additional storage tanks must be the same capacity as the main TankBoost unit.
- The tanks must be located next to each other and on the same level.
- The total volume of stored water must not be more than will be used in a single day.
- The supplied tank connector kit should be used to link the tanks.