
Fitting Instructions for VARILIGHT Wiring Accessories

Please read these instructions carefully before beginning any electrical work and retain them for future reference. The product should be installed in accordance with the current addition of the IEE Wiring regulations. If in doubt, consult a qualified electrician.

- 1. Always switch OFF the mains supply and remove the appropriate fuse or switch off the appropriate circuit breaker before beginning electrical work.
- 2. Always use cable of the correct rating and type.
- 3. The layout of the terminals may differ between fittings so check the location of terminal connections carefully before wiring.
- 4. Make electrical connections according to the relevant diagram ensuring no bare wires protrude from the terminals. Please ensure all terminals on each product are securely tightened, including factory tightened terminals
- 5. If the product has an earth terminal connect the fixed earth wire to it and then connect a short length of wire from the earth terminal on the product to the earth terminal on the wall box. The earth wire should be sheathed with green and yellow sleeving.
- 6. Screw plate to wall using fixing screws supplied.
- 7. Switch on the mains supply.


WARNING: Do not apply products with metal faceplates directly to freshly plastered or damp surfaces as product may tarnish. If in doubt, use polythene as a temporary gasket to protect the product. Do not use masking tape on metal faceplates




For 2 or more gangs the live wire may be connected to each COM terminal by means of a short length of sleeved wire.

WIRING - 2A, 5A, 13A SOCKETS

All sockets must be earthed and check earth leads adequately sleeved. Connect the earth wire(s) to the terminal marked with an earth symbol. Connect the live wire(s) to the terminal marked L. Connect the neutral wire(s) to the terminal marked L.







FAN ISOLATORS


Can be wired using the above configuration. The third pair of terminals should be used for fan units incorporating timers.



TELEPHONE SOCKETS
Master sockets should
only be fitted by an
authorised engineer.
When fitting a telephone
slave as an extension,
simply connect terminals
2, 3, 4 & 5 on the master
unit co the same
terminal number on the
slave unit with the same
cable colour.







Guarantee: If this item becomes defective within 10 years of purchase, Varilight undertakes to repair or replace the item, at its discretion, and solely as a result of faulty materials or workmanship, provided that the unit has been correctly fitted according to the instructions, has not been used overloaded beyond its rating, tampered with or taken apart. Pack the unit securely and return it to: Service Department, Carylls Lea, Faygate, Horsham, West Sussex, RH 12 4SJ (Tel. +44(01293) 223333), together with a letter stating the guarantee registration number below, the date and place of purchase, the type and wattage of the lighting or other load being controlled and the details of the fault. This guarantee states Varilight's entire liability, which does not extend to cover consequential loss or damage or installation costs arising from a defective product. This guarantee does not in any way affect the statutory rights of the purchaser and is offered so that you may have the benefit of our technical facilities. **Guarantee Registration Number: WA005**

Recycling services for end-of-life electrical products should be offered by your local authority. Recycling services for metal faceplates may also be available in your locality.

Doyle & Tratt Products Ltd, Carylls Lea, Faygate, Horsham, W. Sussex, RH12 4SJ, UK. +44 (01293) 223333 Varilight Europe Kft, 2600 Vác, Althann Mihály Frigyes utca 2, Hungary.

